STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155206	A. BUILDING 01 B. WING _____	07/03/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
BROWNSBURG HEALTH CARE CENTER	1010 HORNADAY RD BROWNSBURG, IN 46112

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 07/03/12 Facility Number: 000113 Provider Number: 155206 AIM Number: 100287670 Surveyor: Dennis Austill, Life Safety Code Supervisor At this Quality Assurance Walk-thru Survey, Brownsburg Health Care Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type III (200) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection on all levels including the corridors, spaces open to the corridors and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 160 and had a census of 110 at the time of this survey. The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage. All areas where residents have customary access	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155206	A. BUILDING 01 B. WING _____	07/03/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
BROWNSBURG HEALTH CARE CENTER	1010 HORNADAY RD BROWNSBURG, IN 46112

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 were sprinklered. The facility had one detached building providing facility services, a brick exterior wood frame garage used as a maintenance shop which was not sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 07/09/12.	K 000		